

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M129

Asset: P.S. 129 - MANHATTAN, 425 WEST 130 STREET, MANHATTAN, NY, 10027

Inspection Id	Inspection Type	Time In	Last Edited
2426	MECHANICAL	2024-01-16 07:50AM	2024-02-28 08:30PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Climate Control System - Air Compressor, Refrigerated Air Dryers, Pneumatic PRV Station Years: 2023 Systems: DX Split Systems for Auditorium Years: 2022 Systems: Science Lab, Science Prep Room; Terminal Unit Thermostatic Traps (~80%); F&T/Steam Drip Traps; Electric Domestic Water Heater (in 1st Floor - Gym Slop Sink Closet) Years: 2018 Systems: Boiler Fresh Air Louver/Dampers; MDF Room - Dedicated A/C Equipment (1 of 2, Window A/C) Years: 2015 Systems: Water Service Years: 2014
Are there fuel tanks?	Yes
Total # of above ground tanks	1
Total capacity of all above ground tanks in gal.	10,000
Total # of below ground tanks	0
Total capacity of all below ground tanks in gal.	0
Total # of water main service entries to the asset	2
MERs/Fan Rooms Locations	MER 202
Are there any spaces with Missing or Defective CO Detectors?	Yes
Location(s)	Kitchen
Are there any Painted/Obstructed Sprinkler Heads?	Yes
Location(s)	Rooms B19, 118, 218 (painted, 7)
Are there any Emergency Stop Switches with Missing Hammers?	No components

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

Inspection

Question	Response
Mechanical	
AIR CONDITIONING	Inspected
Chilled Water System	Does not exist
Condenser Water Distribution: Piping, Pumps and Auxiliaries	Does not exist
Cooling Coil in Ductwork	Does not exist
Cooling Tower	Does not exist
DX Split System	Inspected
Indoor Unit	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Outdoor Unit	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Dry Cooler	Does not exist
Packaged / Rooftop Unit	Does not exist
Packaged Terminal A/C	Does not exist
Refrigerant Leak Detection System	Does not exist
Refrigerant Piping	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M129

Question	Response
AIR CONDITIONING	
Refrigerant Piping	
Condition	1- Good
Deficiency	No deficiencies recorded
Return Fan	Does not exist
CENTRAL ACID WASTE NEUTRALIZING TANK	Does not exist
CLIMATE CONTROL SYSTEM	Inspected
BMS	Does not exist
Pneumatic System	Inspected
Instance	Throughout
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Building Area Covered by Operational System	81-100%
Deficiency	PNEUMATIC TUBING: DEFECTIVE/LEAKS AIR
Deficiency Location/Instance	Rooms 102, 213, 229, 234
Deficiency Quantity	40
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DEFECTIVE TEMPERATURE CONTROL THERMOSTAT
Deficiency Location/Instance	Room 128
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Hybrid System	Does not exist
Electric System	Does not exist
COMPACTOR	Does not exist
CONVEYING	Does not exist
DOMESTIC WATER SYSTEM	Inspected
Domestic Cold Water System	Inspected
Gravity System	Does not exist
Pressure Booster System	Does not exist
Water Service	Inspected
Instance	Basement Crawlspace - Convent Avenue Side, 130th Street Side
Instance Condition	1- Good
Instance Quantity	2
Instance Quantity Uom	EACH
Deficiency	WATER MAIN:MISSING BACKFLOW PREVENTION DEVICE
Deficiency Location/Instance	Basement Crawlspace - Convent Avenue Side, 130th Street Side
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	WATER MAIN:DEFECTIVE VALVE
Deficiency Location/Instance	Basement Crawlspace - Convent Avenue Side
Deficiency Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M129

Question	Response
DOMESTIC WATER SYSTEM	
Domestic Cold Water System	
Water Service	
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Domestic Hot Water System	Inspected
Domestic Hot Water Remote Storage Tank	Does not exist
Domestic Water Heat Exchanger	Inaccessible
Electric Domestic Water Heater	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Gas Fired Domestic Water Heater	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	RayPak
EquipmentId	N/A
Capacity/Size Quantity	264
Capacity/Size UOM	MBH Input
Capacity/Size 2 Quantity	0
Capacity/Size 2 UOM	Gallons
Source of Capacity/Size	Documented
Installation Year	2011
Source of Installation Year	Custodial Staff
Deficiency	No deficiencies recorded
Oil Fired Domestic Water Heater	Does not exist
Heat Pump Domestic Water Heater	Does not exist
Domestic Water Distribution Piping	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE VALVE
Deficiency Location/Instance	Basement Crawlspace - Convent Avenue Side
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
DRAIN/WASTE/VENT AND STORM SYSTEM	Inspected
Interior Storm Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Sewage/Waste/Vent Piping	Inspected
Condition	3- Fair
Deficiency	SEWAGE/WASTE PIPING:DEFECTIVE/LEAKS
Deficiency Location/Instance	Girl's Toilet Rooms 120, 220
Deficiency Quantity	20
Quantity Uom	L.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Sewage Ejector Pump	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M129

Question	Response
DRAIN/WASTE/VENT AND STORM SYSTEM	
Sump Pump	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE MOTOR
Deficiency Location/Instance	Boiler Room (1 of 2)
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
DUAL TEMPERATURE SYSTEM (CHILLED AND HOT WATER)	Does not exist
FIXTURES	Inspected
Staff And Other	Inspected
Janitor Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lavatory/Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Urinal	Inspected
Condition	5- Poor
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Men's Toilet Rooms B6, inside Room B17
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Student	Inspected
Drinking Fountain	Inspected
Condition	3- Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Gymnasium
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Lavatory/Sink	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Locker Room Shower	Inspected
Instance on 1st Floor - Boys	Inaccessible
Instance on 1st Floor - Girls	Inaccessible
Sink And Fountain Combo Unit	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Toilet	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M129

Question	Response
FIXTURES	
Student	
Toilet	
Condition	3- Fair
Deficiency	DEFECTIVE FLUSHOMETER VALVE
Deficiency Location/Instance	Girl's Toilet Room 220
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Urinal	Inspected
Condition	3- Fair
Deficiency	CRACKED/PHYSICAL DAMAGE
Deficiency Location/Instance	Boy's Toilet Rooms B13, 224
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
GAS FIRED FURNACE	Does not exist
GAS SERVICE	Inspected
Gas Distribution Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Gas Meter Room Exhaust Fan	Does not exist
Gas Meter Room Vent	Does not exist
Gas Pressure Booster	Does not exist
CO/Gas Leak Detection	Does not exist
HEATING	Inspected
Heating Coil In Ductwork	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Hydronic Heating	Does not exist
Radiator/Convactor/Fin Tube	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Steam Heating	Inspected
F&T/Steam Drip Trap	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
MER Steam and Condensate Piping	Inspected
Condition	3- Fair
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Location/Instance	MER 202
Deficiency Quantity	40
Quantity Uom	L.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Condensate Return Piping	Inspected
Condition	3- Fair

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M129

Question	Response
HEATING	
Steam Heating	
Steam Condensate Return Piping	
Deficiency	No deficiencies recorded
Steam Condensate Return Pumping System	Inspected
Condition	5- Poor
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Steam Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Terminal Unit Thermostatic Trap	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Steam supplied by External Sources	Does not exist
Unit Heater/Cabinet Heater	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
HEATING PLANT	Inspected
Instance on Basement	Inspected
Is there a water meter on the boiler make-up water piping?	No
Burner Manufacturer	Preferred Utilities
Burner Model	BHE 6 3A4
Burner Type	Oil
Heating Plant Oil Number	4
Boiler Auxiliaries	
Instance on Basement	Inspected
Boiler Auxiliary Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	DEFECTIVE BOILER AUTOMATIC FEEDWATER VALVE
Deficiency Location/Instance	Boiler Room @ Boiler #2
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Emergency Stop Switch	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Feedwater System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	FEEDWATER PUMP:DEFECTIVE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M129

Question	Response
HEATING PLANT	
Boiler Auxiliaries	
Boiler Feedwater System	
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Boiler Feedwater Treatment(Automatic)	
Instance on Basement	Does not exist
Boiler Flue Exhaust	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Make-up Water Backflow Preventer	
Instance on Basement	Does not exist
Boiler Room Steam And Condensate Piping	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler Safety Valve	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Boiler System	
Instance on Basement	Inspected
Coal-fired Boiler	
Instance on Basement	Does not exist
Hot Water Boiler	
Instance on Basement	Does not exist
Modular Boiler	
Instance on Basement	Does not exist
Steam Boiler	
Instance on Basement	Inspected
Instance on Basement	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	3,422
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	Fitzgibbons Boiler Company
EquipmentId	46421-1
Capacity/Size Quantity	38
Capacity/Size UOM	Burner GPH
Source of Capacity/Size	Documented
Installation Year	1957
Source of Installation Year	Documented
Deficiency	LEAKY/PLUGGED TUBES
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Quantity	20

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M129

Question	Response
HEATING PLANT	
Boiler System	
Steam Boiler	
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	3,422
Instance Quantity Uom	MBH NET
Cast Iron Boiler?	No
Manufacturer	Fitzgibbons Boiler Company
EquipmentId	46421-2
Capacity/Size Quantity	38
Capacity/Size UOM	Burner GPH
Source of Capacity/Size	Documented
Installation Year	1957
Source of Installation Year	Documented
Deficiency	DAMAGED REFRACTORY
Deficiency Quantity	10
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Deficiency	DAMAGED/MISSING INSULATION
Deficiency Quantity	30
Quantity Uom	S.F.
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fuel System	
Instance on Basement	Inspected
Boiler Fresh Air Louver/Damper	
Instance on Basement	Inspected
Instance Condition	1- Good
Type	Automatic
Deficiency	DEFECTIVE DAMPER
Deficiency Location/Instance	Boiler Room @ Boiler #1
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Burner/Burner Control Panel	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Fuel Oil Storage/Supply System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	FUEL OIL PIPING:DEFECTIVE/LEAKS

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M129

Question	Response
HEATING PLANT	
Fuel System	
Fuel Oil Storage/Supply System	
Deficiency Location/Instance	Boiler Room @ Boiler #2
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
Gas Trains And Vent At The Boiler	
Instance on Basement	Does not exist
Enclosed IDF Room	
Instance on Rooms 118, 216, 316	Inspected
Dedicated A/C Equipment	
Instance on Rooms 118, 216, 316	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DOES NOT EXIST
Deficiency Location/Instance	Rooms 118, 216, 316
Deficiency Quantity	3
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
KITCHEN	
Instance on Basement	Inspected
CO Detector	
Instance on Basement	Inspected
Instance Condition	4- Between Fair and Poor
Deficiency	DEFECTIVE/MISSING
Deficiency Location/Instance	Kitchen
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	MAINTENANCE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Gas System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Grease Trap	
Instance on Basement	Does not exist
Hood	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Hood Exhaust Fan	
Instance on Basement	Inspected
Instance Condition	3- Fair

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M129

Question	Response
KITCHEN	
Hood Exhaust Fan	
Deficiency	No deficiencies recorded
Hood Fire Suppression System	
Instance on Basement	Does not exist
Hot Water Temperature Booster	
Instance on Basement	Does not exist
Kitchen Sink	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	MISSING INDIRECT WASTE
Deficiency Location/Instance	Kitchen
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	INSTALL
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 4
Violations	SF103571
MDF Room	Inspected
Instance on Room 218	Inspected
Dedicated A/C Equipment	
Instance on Room 218	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
SCIENCE DEMO ROOM	Does not exist
SCIENCE LAB	Inspected
Instance on Room 302	Inspected
Alternative Use	No
Acid Waste Neutralizing Tank	
Instance on Room 302	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
CO Detector	
Instance on Room 302	Not required
Emergency Shower	
Instance on Room 302	Does not exist
Eye Wash	
Instance on Room 302	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Hood Exhaust Ductwork	
Instance on Room 302	Does not exist
Hood Exhaust Fan	
Instance on Room 302	Does not exist
Fixed Laboratory Hood	
Instance on Room 302	Does not exist
Laboratory Sink	
Instance on Room 302	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Make-up Air Unit	
Instance on Room 302	Does not exist
SCIENCE PREP ROOM	Inspected
Instance on Room 304	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M129

Question	Response
SCIENCE PREP ROOM	
Alternative Use	Yes
Acid Waste Neutralizing Tank	
Instance on Room 304	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
CO Detector	
Instance on Room 304	Not required
Emergency Shower	
Instance on Room 304	Does not exist
Eye Wash	
Instance on Room 304	Does not exist
Hood Exhaust Ductwork	
Instance on Room 304	Does not exist
Hood Exhaust Fan	
Instance on Room 304	Does not exist
Fixed Laboratory Hood	
Instance on Room 304	Does not exist
Laboratory Sink	
Instance on Room 304	Inspected
Instance Condition	1- Good
Deficiency	No deficiencies recorded
Make-up Air Unit	
Instance on Room 304	Does not exist
SPRINKLERS, STANDPIPE, FIRE SYSTEM	Inspected
Dry Sprinkler Alarm Valve Assembly	Does not exist
Wet Sprinkler Alarm Valve Assembly	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Booster Pump Assembly	Does not exist
Roof Tank	Does not exist
Siamese Connection	Does not exist
Sprinkler Head	Inspected
Condition	3- Fair
Deficiency	DEFECTIVE/DETERIORATED
Deficiency Location/Instance	Rooms B19, 118, 218 (painted, 7)
Deficiency Quantity	7
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 6
Violations	No violations recorded
Sprinkler Piping	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standpipe System	Does not exist
Water Gong	Does not exist
SWIMMING POOL	Does not exist
VENTILATION	Inspected
Is the building Mechanically ventilated?	Partial
Exhaust Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-25
Deficiency	No deficiencies recorded
Heating And Ventilating Unit	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Mechanical Inspection

M129

Question	Response
VENTILATION	
Metal Ductwork	Inspected
Condition	3- Fair
Are there any uninsulated ductwork by design in Mechanical rooms?	Yes
Are there chain operated dampers?	No
Deficiency	No deficiencies recorded
Supply Fan	Inspected
Condition	3- Fair
Approximate Total # of Fans	1-5
Deficiency	No deficiencies recorded
Unit Ventilator	Does not exist