

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Asset: I.S. 7 - STATEN ISLAND, 1270 HUGUENOT AVENUE, STATEN ISLAND, NY, 10312

Inspection Id	Inspection Type	Time In	Last Edited
3958	ELECTRICAL	2024-03-13 07:36AM	2024-04-04 01:57PM

Asset Data

Question	Answer
Have any Systems/Major Building Components been upgraded?	Systems: Auditorium (Retrofitted LED Lighting), LAN Years: 2022 Systems: Most Lighting - Security Years: 2020 Systems: Partial Molded Case Circuit Breaker Panel Board Years: 2019, 2016, 2009, 2004, 1995 Systems: Auditorium (Partial Theater Lighting, Dimming System, Local Sound System) Years: 2019 Systems: Library (Raceway With Receptacles) Years: 2017 Systems: Gymnasium (LED Lighting) Years: 2015 Systems: Exit Lights (Battery Pack), Intrusion Alarm System (Central Control Panel) Years: 2013 Systems: IPDVS/CCTV System Years: 2011 Systems: Partial Service Switch Years: 2009, 2004 Systems: Public Address System, Local Sound System (Gymnasium, Cafeteria) Years: 2007 Systems: Science Lab - Room 114 (Incandescent Lighting) Years: 2004 Systems: Emergency Light/Exit Light Panel, Intrusion Alarm System, Partial Fused Disconnect Switch Type Panel Board Years: 2001 Systems: Interior Fluorescent Lighting, Retrofitted Fluorescent Lighting (Corridors) Years: 2000
Type of Service	Below Ground
Does Interactive Whiteboard (IWB) Exist?	Yes
Water Penetration In Electrical Room?	No

DEDICATED INTERCOMS IN FIRE RESCUE AREAS

Question	Response
Are there any Life Rescue Assistance Areas, Fire Rescue Areas, and/or Holding Rooms in your building?	No

Priority Condition

Exist Last Year?	Priority Category	Condition Description	Component Affected	Location Description	Person(s) Notified	Person(s) Title	Photo Image
No condition recorded							

Inspection

Question	Response
Electrical	
ATHLETIC FIELD	Does not exist
AUDITORIUM	Inspected
Instance on 1st Floor	Inspected
House Lighting	
Instance on 1st Floor	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
AUDITORIUM	
House Lighting	
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	2
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Does not exist
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Installation Year	2019
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not exist
Theater Lighting System	
Instance on 1st Floor	Inspected
Dimming System	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
AUDITORIUM	
Theater Lighting System	
Dimming System	
Deficiency	No deficiencies recorded
Theater Lighting	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	112
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
CAFETERIA	
Instance on Basement	Inspected
Instance on Basement	Inspected
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Does not exist
Lighting Fixture - LED	
Instance on Basement	Does not exist
Local Sound System	
Instance on Basement	Inspected
Instance Condition	3- Fair
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on Basement	Does not exist
Theater Lighting System	
Instance on Basement	Does not exist
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Instance on Basement	Inspected
Lighting	
Does a Chandelier Exist?	No
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Basement	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
CLASSROOM/CORRIDOR/ADMINISTRATIVE SPACE	
Lighting	
Lighting Fixture - Fluorescent	
Recessed Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
COMPUTER LAB	Inspected
Instance on Room 329	Inspected
Power Panel?	Yes
Lighting	
Instance on Room 329	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 329	Inspected
Pendant Mounted	
Instance on Room 329	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 329	Does not exist
Recessed Mounted	
Instance on Room 329	Does not exist
Lighting Fixture - HID	
Instance on Room 329	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 329	Does not exist
Lighting Fixture - LED	
Instance on Room 329	Does not exist
Raceway With Receptacles	
Instance on Room 329	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
GYMNASIUM	Inspected
Instance on 1st Floor	Inspected
Lighting	
Instance on 1st Floor	Inspected
Lighting Fixture - Fluorescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - HID	
Instance on 1st Floor	Does not exist
Lighting Fixture - Incandescent	
Instance on 1st Floor	Does not exist
Lighting Fixture - LED	
Instance on 1st Floor	Inspected
Pendant Mounted	
Instance on 1st Floor	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on 1st Floor	Does not exist
Recessed Mounted	
Instance on 1st Floor	Does not exist

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
GYMNASIUM	
Lighting	
Lighting Fixture - LED	
Recessed Mounted	
Local Sound System	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Installation Year	2007
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Projection System	
Instance on 1st Floor	Does not exist
Scoreboard	
Instance on 1st Floor	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Theater Lighting System	
Instance on 1st Floor	Does not exist
KITCHEN	
Instance on Basement	Inspected
Lighting	
Instance on Basement	Inspected
Lighting Fixture - Fluorescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Does not exist
Surface Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Basement	Does not exist
Lighting Fixture - HID	
Instance on Basement	Does not exist
Lighting Fixture - Incandescent	
Instance on Basement	Inspected
Pendant Mounted	
Instance on Basement	Inspected
Instance Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Surface Mounted	
Instance on Basement	Does not exist
Recessed Mounted	
Instance on Basement	Does not exist
Lighting Fixture - LED	
Instance on Basement	Does not exist
LIBRARY	
Instance on Room 236	Inspected

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
LIBRARY	
Lighting	
Instance on Room 236	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 236	Inspected
Pendant Mounted	
Instance on Room 236	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 236	Does not exist
Recessed Mounted	
Instance on Room 236	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting Fixture - HID	
Instance on Room 236	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 236	Does not exist
Lighting Fixture - LED	
Instance on Room 236	Does not exist
Raceway With Receptacles	
Instance on Room 236	Inspected
Instance Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Projection System	
Instance on Room 236	Does not exist
LOCKER ROOM	Does not exist
MULTIPURPOSE ROOM	Does not exist
SCIENCE DEMO ROOM	Inspected
Instance on Rooms: 118, 222, 226	Inspected
Power Panel?	No
Alternative Use	No
Instance on Rooms: 318, 322	Inspected
Power Panel?	No
Alternative Use	No
Lighting	
Instance on Rooms: 118, 222, 226	Inspected
Instance on Rooms: 318, 322	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms: 118, 222, 226	Inspected
Instance on Rooms: 318, 322	Inspected
Pendant Mounted	
Instance on Rooms: 118, 222, 226	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Instance on Rooms: 318, 322	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Rooms: 118, 222, 226	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
SCIENCE DEMO ROOM	
Lighting	
Lighting Fixture - Fluorescent	
Surface Mounted	
Instance on Rooms: 318, 322	Does not exist
Recessed Mounted	
Instance on Rooms: 118, 222, 226	Does not exist
Instance on Rooms: 318, 322	Does not exist
Lighting Fixture - HID	
Instance on Rooms: 118, 222, 226	Does not exist
Instance on Rooms: 318, 322	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms: 118, 222, 226	Does not exist
Instance on Rooms: 318, 322	Does not exist
Lighting Fixture - LED	
Instance on Rooms: 118, 222, 226	Does not exist
Instance on Rooms: 318, 322	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Rooms: 118, 222, 226	Does not exist
Instance on Rooms: 318, 322	Does not exist
Emergency Shut-Off Power	
Instance on Rooms: 118, 222, 226	Does not exist
Instance on Rooms: 318, 322	Does not exist
Power Supply	
Instance on Rooms: 118, 222, 226	Does not exist
Instance on Rooms: 318, 322	Does not exist
Projection System	
Instance on Rooms: 118, 222, 226	Does not exist
Instance on Rooms: 318, 322	Does not exist
SCIENCE LAB	Inspected
Instance on Room 114	Inspected
Power Panel?	Yes
Alternative Use	No
Lighting	
Instance on Room 114	Inspected
Lighting Fixture - Fluorescent	
Instance on Room 114	Inspected
Pendant Mounted	
Instance on Room 114	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Room 114	Does not exist
Recessed Mounted	
Instance on Room 114	Does not exist
Lighting Fixture - HID	
Instance on Room 114	Does not exist
Lighting Fixture - Incandescent	
Instance on Room 114	Inspected
Pendant Mounted	
Instance on Room 114	Does not exist
Surface Mounted	
Instance on Room 114	Inspected
Instance Condition	3- Fair

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
SCIENCE LAB	
Lighting	
Lighting Fixture - Incandescent	
Surface Mounted	
Deficiency	No deficiencies recorded
Recessed Mounted	
Instance on Room 114	Does not exist
Lighting Fixture - LED	
Instance on Room 114	Does not exist
Emergency Gas Shut-Off Valve	
Instance on Room 114	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Room 114	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Power Supply	
Instance on Room 114	Inspected
Instructor Unit	
Instance on Room 114	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Meter Demonstration Unit	
Instance on Room 114	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Student Unit	
Instance on Room 114	Does not exist
Projection System	
Instance on Room 114	Does not exist
SCIENCE PREP ROOM	Inspected
Instance on Rooms: 116, 224, 320	Inspected
Power Panel?	No
Alternative Use	No
Lighting	
Instance on Rooms: 116, 224, 320	Inspected
Lighting Fixture - Fluorescent	
Instance on Rooms: 116, 224, 320	Inspected
Pendant Mounted	
Instance on Rooms: 116, 224, 320	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Surface Mounted	
Instance on Rooms: 116, 224, 320	Does not exist
Recessed Mounted	
Instance on Rooms: 116, 224, 320	Does not exist
Lighting Fixture - HID	
Instance on Rooms: 116, 224, 320	Does not exist
Lighting Fixture - Incandescent	
Instance on Rooms: 116, 224, 320	Does not exist
Lighting Fixture - LED	
Instance on Rooms: 116, 224, 320	Does not exist
Emergency Gas Shut-Off Valve	

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
SCIENCE PREP ROOM	
Emergency Gas Shut-Off Valve	
Instance on Rooms: 116, 224, 320	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Emergency Shut-Off Power	
Instance on Rooms: 116, 224, 320	Inspected
Instance Condition	3- Fair
Deficiency	No deficiencies recorded
Power Supply	
Instance on Rooms: 116, 224, 320	Does not exist
SWIMMING POOL	Does not exist
TOILET ROOM - STAFF	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Does not exist
Lighting Fixture - LED	Does not exist
TOILET ROOM - STUDENT	Inspected
Lighting	Inspected
Lighting Fixture - Fluorescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Recessed Mounted	Does not exist
Lighting Fixture - HID	Does not exist
Lighting Fixture - Incandescent	Inspected
Pendant Mounted	Does not exist
Surface Mounted	Inspected
Condition	3- Fair
Deficiency	LIGHTING FIXTURE BEYOND USEFUL LIFE
Deficiency Quantity	5
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Recessed Mounted	Does not exist
Lighting Fixture - LED	Does not exist
AUXILIARY SIGNAL/BELL SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EMERGENCY DC STANDBY BATTERY POWER	Does not exist
EMERGENCY GENERATOR SET	Does not exist
EMERGENCY LIGHT/EXIT LIGHT PANEL	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
EMERGENCY LIGHTING	Inspected
Battery Pack	Inspected
Condition	3- Fair
Deficiency	BATTERY NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	9
Quantity Uom	EACH
Potential Action	REPLACE BATTERY
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Non Battery Pack	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
EXIT LIGHT	Inspected
Battery Pack	Inspected
Condition	2- Between Good and Fair
Deficiency	No deficiencies recorded
Non Battery Pack	Does not exist
EXIT/EMERGENCY LIGHT	Does not exist
FIRE ALARM SYSTEM	Inspected
Bell/Horn	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Strobe	Does not exist
Manual Pull Station	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fan Shutdown Control	Does not exist
Duct Smoke Detector	Does not exist
Area Smoke Detector	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
CO Detector	Does not exist
Heat Detector	Does not exist
Elevator Recall	Does not exist
Magnetic Door Holder/Contactor	Does not exist
Fused Cutout Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Digital Communicator	Does not exist
Main Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Does not exist
Fire Alarm Control Panel (Standard)	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
EquipmentId	Fire Signal Control Board
Installation Year	1965
Source of Installation Year	Documented

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
FIRE ALARM SYSTEM	
Main Panel	
Fire Alarm Control Panel (Standard)	
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	160,000
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Sub-Panel	Inspected
Bell At Panel	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Fire Alarm Control Panel (Electronic)	Does not exist
Fire Alarm Control Panel (Standard)	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
EquipmentId	Sprinkler Alarm Central Panel
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	160,000
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Edwards
EquipmentId	Punch Register Control Panel
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	160,000
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Auditorium Stage
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Fire Control Inc
EquipmentId	N/A

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
FIRE ALARM SYSTEM	
Sub-Panel	
Fire Alarm Control Panel (Standard)	
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Auditorium Stage
Deficiency Quantity	160,000
Quantity Uom	S.F.
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Remote Annunciator	Inspected
Display Monitor	Does not exist
Panel	Does not exist
Printer	Does not exist
Punch Register	Inspected
Condition	5- Poor
Deficiency	REGISTER NOT OPERATIONAL
Deficiency Location/Instance	Custodian's Office
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 5
Purpose of Action	LEVEL 2
Violations	No violations recorded
Sprinkler Flow/Air Pressure Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Tamper Flow Switch/Chain	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
GROUNDING SYSTEM	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
INTERCOM SYSTEM	Does not exist
LAN	Inspected
Local Distribution Frame (I/LDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
Main Equipment Rack (MDF)	Inspected
Condition	1- Good
Deficiency	No deficiencies recorded
LIGHTNING PROTECTION	Does not exist
MOTOR CONTROLLER	Inspected
MOTOR CONTROL CENTER	Does not exist
MOTOR STARTER/CONTACTOR	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Variable Frequency Drive	Does not exist
PANEL BOARD	Inspected
Fused Disconnect Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
PANEL BOARD	
Fused Disconnect Switch Type	
Deficiency Location/Instance	Boiler Room, Fan Rooms: B1 and 202
Deficiency Quantity	4
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Fused Toggle Switch Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B26
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Molded Case Circuit Breaker Type	Inspected
Condition	3- Fair
Deficiency	PANEL BOARD BEYOND USEFUL LIFE
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	23
Quantity Uom	EACH
Potential Action	REPLACE-UPGRADE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
PUBLIC ADDRESS SYSTEM	Inspected
Instance	Main Office - Room 130
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Dukane 250
Installation Year	2007
Source of Installation Year	Documented
Deficiency	CLOCK NOT OPERATIONAL
Deficiency Location/Instance	Throughout the Building
Deficiency Quantity	11
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 3
Purpose of Action	LEVEL 2
Violations	No violations recorded
SECURITY	Inspected
IPDVS/CCTV System	Inspected
Condition	3- Fair
Installation Year	2011
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Intrusion Alarm System	Inspected
Central Control Panel	Inspected
Instance	Custodian's Office - Room 128
Instance Condition	2- Between Good and Fair

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
SECURITY	
Intrusion Alarm System	
Central Control Panel	
Instance Quantity	1
Instance Quantity Uom	EACH
Model	Vista - 128B
Installation Year	2013
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Infrared Sensor	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Panic Switch	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Remote Annunciator	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Siren/Strobe	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Lighting - Security	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
SERVICE SWITCH	Inspected
Instance	Electrical Room B26
Instance Condition	2- Between Good and Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	EATON
EquipmentId	Feeder for Panels ACPP-2A&ACPP-2B
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2009
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
Instance	Electrical Room B26
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	HTG EQ. PWR. PNL
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B26
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
SERVICE SWITCH	
Violations	No violations recorded
Instance	Electrical Room B26
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	Service No. 1 Power
Capacity/Size Quantity	800
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B26
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B26
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	Service No. 1 Light
Capacity/Size Quantity	800
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B26
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B26
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	Service No. 2 Power
Capacity/Size Quantity	800
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B26
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
SERVICE SWITCH	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B26
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	Service No. 2 Light
Capacity/Size Quantity	800
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B26
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B26
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	General Electric
EquipmentId	Switch for CD-PP
Capacity/Size Quantity	400
Capacity/Size UOM	Amps
Source of Capacity/Size	Nameplate
Installation Year	2004
Source of Installation Year	Documented
Deficiency	No deficiencies recorded
SWITCHBOARD	Inspected
Number of Spares	2
Fused Disconnect Switch Type	Inspected
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	Main SWBD No. 2 Power Sect.
Capacity/Size Quantity	800
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Boiler Room
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	Main SWBD No. 2 Lighting Sect.
Capacity/Size Quantity	800
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Boiler Room
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B26
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	Main SWBD No. 1 Power Sect.
Capacity/Size Quantity	800
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	2
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B26
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Instance	Electrical Room B26
Instance Condition	3- Fair
Instance Quantity	1
Instance Quantity Uom	EACH
Manufacturer	Empire Switchboard
EquipmentId	Main SWBD No. 2 Lighting Sect.
Capacity/Size Quantity	800
Capacity/Size UOM	Amps Total
Capacity/Size 2 Quantity	1

NYC Department of Education
Building Condition Assessment Survey 2023-2024

Electrical Inspection

R007

Question	Response
SWITCHBOARD	
Fused Disconnect Switch Type	
Capacity/Size 2 UOM	Section(s)
Source of Capacity/Size	Service Switch Size
Installation Year	1965
Source of Installation Year	Documented
Deficiency	BEYOND USEFUL LIFE
Deficiency Location/Instance	Electrical Room B26
Deficiency Quantity	1
Quantity Uom	EACH
Potential Action	REPLACE
Urgency of Action	PRIORITY 1
Purpose of Action	LEVEL 2
Violations	No violations recorded
Fused Knife Switch Type	Does not exist
Molded Case Circuit Breaker Type	Does not exist
TELEPHONE SYSTEM	Inspected
PBX/Intercom	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
Standard	Inspected
Condition	3- Fair
Deficiency	No deficiencies recorded
TRANSFORMER	Does not exist